

Energieproduktion der Solaranlage Löhracker, Aadorf

(alle Werte in kWh)

	Sollproduktion	Jahresschnitt ab 1997	2007 Rekordjahr	2008 gutes Jahr	2009 Teilausfall Messung	2010 Teilausfall Messung	2011 Spitzenjahr	2012 normales Jahr	2013 Teilausfall Messung	2014 Teilausfall Daten-Ü	2015 Teilausfall Daten-Ü
Januar	192.00	167.07	182.00	283.00	122.00	108.00	117.00	196.00	101.17	210.00	152.00
Februar	294.00	243.70	384.00	542.00	157.00	220.00	306.00	202.00	46.63	345.00	111.00
März	476.00	521.55	587.00	542.00	459.00	548.00	636.00	754.00	318.26	654.00	628.00
April	613.00	663.59	969.00	599.00	805.00	813.00	910.00	604.00	499.94	699.00	718.00
Mai	752.00	789.26	885.00	912.00	885.00	627.00	984.00	915.00	675.00	786.00	856.00
Juni	748.00	827.23	830.00	812.00	870.00	762.00	750.00	826.00	783.00	933.00	830.40
Juli	828.00	806.61	884.00	907.00	866.00	698.00	818.00	808.00	946.00	698.00	905.30
August	800.00	725.47	724.00	800.00	891.00	528.00	882.00	872.00	810.00	692.00	792.40
September	525.00	580.34	659.00	533.00	623.00	646.00	664.00	567.00	562.00	578.00	541.30
Oktober	343.00	380.20	411.00	420.00	441.00	385.00	426.00	333.00	352.00	416.00	316.30
November	179.00	206.49	195.00	137.00	267.00	204.00	202.00	199.00	156.00	197.00	295.40
Dezember	154.00	132.55	149.00	84.00	101.00	32.00	142.00	115.00	300.00	126.00	268.90
Maximum:	828.00	827.23	969.00	912.00	891.00	813.00	984.00	915.00	946.00	933.00	905.30
Minimum:	154.00	132.55	149.00	84.00	101.00	32.00	117.00	115.00	46.63	126.00	111.00
Summe:	5904.00	6044.06	6859.00	6571.00	6487.00	5571.00	6837.00	6391.00	5550.00	6334.00	6415.00
Total:			67511.09	74082.09	80569.09	86140.09	92977.09	99368.09	104918.1	111252.1	117667.1

