

Energieproduktion der Solaranlage Löhracker, Aadorf

(alle Werte in kWh)

	Soll- produk- tion	Jahres- schnitt ab 1997	2011 Spitzen- jahr	2012 normales Jahr	2013 Teilausfall Messung	2014 Teilausfall Daten-Ü	2015 Teilausfall Daten-Ü	2016 normales Jahr	2017 guter Herbst	2018 gutes Frühjahr	2019 gutes Jahr
Januar	192.00	163.05	117.00	196.00	101.17	210.00	152.00	129.10	81.00	186.80	179.00
Februar	294.00	249.91	306.00	202.00	46.63	345.00	111.00	236.00	302.00	161.00	418.50
März	476.00	523.82	636.00	754.00	318.26	654.00	628.00	480.40	642.70	389.90	625.30
April	613.00	667.99	910.00	604.00	499.94	699.00	718.00	614.90	681.50	833.10	626.10
Mai	752.00	786.18	984.00	915.00	675.00	786.00	856.00	749.80	872.80	757.00	706.60
Juni	748.00	830.34	750.00	826.00	783.00	933.00	830.40	749.80	887.40	875.60	867.60
Juli	828.00	815.17	818.00	808.00	946.00	698.00	905.30	828.60	809.40	893.90	891.50
August	800.00	734.42	882.00	872.00	810.00	692.00	792.40	821.60	757.50	809.70	719.00
September	525.00	591.26	664.00	567.00	562.00	578.00	541.30	674.30	559.50	718.80	620.00
Oktober	343.00	385.81	426.00	333.00	352.00	416.00	316.30	329.10	514.70	434.90	371.30
November	179.00	202.90	202.00	199.00	156.00	197.00	295.40	208.40	186.90	166.90	181.20
Dezember	154.00	136.38	142.00	115.00	300.00	126.00	268.90	231.60	120.40	126.00	140.40
Maximum:	828.00	830.34	984.00	915.00	946.00	933.00	905.30	828.60	887.40	893.90	891.50
Minimum:	154.00	136.38	117.00	115.00	46.63	126.00	111.00	129.10	81.00	126.00	140.40
Summe:	5904.00	6087.24	6837.00	6391.00	5550.00	6334.00	6415.00	6053.60	6415.80	6353.60	6346.50
Total:			92977.09	99368.09	104918.1	111252.1	117667.1	123720.7	130136.5	136490.1	142836.6

